

Evidence of Performance

Variable geometry moving axis unsprung concealed hinge
assembly as per CUAP 04.05/12



Test Report

Nr. 13-000115-PR01
(PB-G02-03-en-02)

Client
ARGENT ALU nv
Bankstraat 2
9770 Kruishoutem
Belgium

Basis
CUAP 04.05/12 2006-08

Test standards:
CUAP 04.05/12 2006-08
EN 1935 : 2002

Product
multi axle door hinges

Designation
"invisible neo M-6"

**Leistungsrelevante
Produktdetails**
Length of hinge: 140 mm;
Material of hinge: Aluminium und Zamak;
Angle of aperture: 180 °;
max. door leaf weight: 80 kg,
Application area: unrebated, blunt doors
Assembly and maintenance
According to maintenance and assembly instructions
of Hardware manufacturer.
Special features
-/-

Corresponding national ver-
sions (e.g. DIN EN)

Representation



Instructions for use

This test report demonstrates
compliance with the require-
ments for hinges as per CUAP
04.05/12 2006-08.

This test report does not re-
place the EC Certificate of Con-
formity.

Observe the provisions of CU-
AP 04.05/12 2006-08 for mark-
ing and evaluation of conformity
of construction products.

Result

Classification as per CUAP 04.05/12

Category of use	Durability	Mass of test element	Fire resis- tance	Safety	Corrosion resistance	Security	Hinge grade
3	7	4	1	1	4	0	11a

Validity

The data and detailed results
given refer solely to the tested
and described test specimens.
Classification remains valid as
long as the product and the
above basis remain unchanged.
This test/evaluation does not
allow any statement to be made
on any further characteristics
regarding performance and
quality of the construction pre-
sented; in particular the effects
of weathering and ageing were
not taken into account.

Notes on publication

The ift Guidance Sheet "Condi-
tions and Guidance for the Use
of ift Test Documents" applies.
The cover sheet can be used
as abstract.

The report comprises a total of
15 page.

ift Rosenheim

21.05.2013

Andreas Matschi, Dipl.-Ing. (FH)
Head of Testing Department
Division Building Components

Alexander Sauer, Dipl.-Ing. (FH)
Operating Product Officer
Division Building Components



ift Rosenheim GmbH
Geschäftsführer:
Dr. Jochen Peichl
Prof. Ulrich Sieberath
Dr. Martin H. Spitzner

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim

Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763

Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PÜZ-Stelle: BAY 18

DAP-ZE-2288.00
DGA-IS-4285-00



Deutsche
Akkreditierungsstelle
D-PL-11349-01-00
D-ZM-11349-01-00