

Evidence of Performance

Variable geometry moving axis unsprung concealed hinge assembly as per CUAP 04.05/12



Test Report

Nr. 13-000115-PR02
(PB-G02-03-en-02)

Client
ARGENT ALU nv
Bankstraat 2
9770 Kruishoutem
Belgium

Basis
CUAP 04.05/12 2006-08

Test standards:
CUAP 04.05/12 2006-08
EN 1935 : 2002

Product
multi axle door hinges

Corresponding national versions (e.g. DIN EN)


Designation
"invisible neo S-5"

Representation

Leistungsrelevante Produktdetails
Length of hinge: 120 mm;
Material of hinge: Aluminium und Zamak;
Angle of aperture: 180 °,
max. door leaf weight: 60 kg,
Application area: unrebated, blunt doors

Assembly and maintenance
According to maintenance and assembly instructions of Hardware manufacturer.

Special features
-/-



Instructions for use

This test report demonstrates compliance with the requirements for hinges as per CUAP 04.05/12 2006-08.

This test report does not replace the EC Certificate of Conformity.

Observe the provisions of CU-AP 04.05/12 2006-08 for marking and evaluation of conformity of construction products.

Result

Classification as per CUAP 04.05/12

Category of use	Durability	Mass of test element	Fire resistance	Safety	Corrosion resistance	Security	Hinge grade
2	7	3	1	1	4	0	10

Validity

The data and detailed results given refer solely to the tested and described test specimens. Classification remains valid as long as the product and the above basis remain unchanged. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

The report comprises a total of 15 page.

ift Rosenheim

21.05.2013

Andreas Matschi, Dipl.-Ing. (FH)
Head of Testing Department
Division Building Components

Alexander Sauer, Dipl.-Ing. (FH)
Operating Product Officer
Division Building Components